

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Indelval SAIC

Carabelas 1022 Villa Madero, Buenos Aires, B1768CMB, Argentina

For the following product(s):

Rubber Stair Treads:

Cerama Tread, Clasica Tread, Deco Tread (*Maximum thickness 4.0mm*)

Wall Base H06 (*Maximum thickness 3.0mm*)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-20165

Valid from: October 01, 2025 to September 30, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink.

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services